

**AMERICAN NATIONAL STANDARD**

**ANSI/ISA-101.01-2015**

**Human Machine Interfaces for  
Process Automation Systems**

**Approved 9 July 2015**

ANSI/ISA-101.01-2015, Human Machine Interfaces for Process Automation Systems

ISBN: 978-1-941546-46-8

Copyright © 2015 by the International Society of Automation. All rights reserved. Printed in the United States of America. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form or by any means (electronic, mechanical, photocopying, recording, or otherwise), without the prior written permission of the publisher.

ISA  
67 Alexander Drive  
P.O. Box 12277  
Research Triangle Park, North Carolina 27709 US

E-mail: [standards@isa.org](mailto:standards@isa.org)

## Preface

This standard has been prepared as part of the service of ISA, the International Society of Automation, toward a goal of uniformity in the field of instrumentation. To be of real value, this document should not be static but should be subject to periodic review. Toward this end, the Society welcomes all comments and criticisms and asks that they be addressed to the Secretary, Standards and Practices Board; ISA, 67 Alexander Drive; P.O. Box 12277; Research Triangle Park, NC 27709; Telephone (919) 549-8411; Fax (919) 549-8288; E-mail: standards@isa.org.

This ISA Standards and Practices Department is aware of the growing need for attention to the metric system of units in general, and the International System of Units (SI) in particular, in the preparation of automation standards, recommended practices, and technical reports. The Department is further aware of the benefits of USA users of ISA standards of incorporating suitable references to the SI (and the metric system) in their business and professional dealings with other countries. Toward this end, the Department will endeavor to introduce SI and acceptable metric units in all new and revised standards to the greatest extent possible. The Metric Practice Guide, which has been published by the Institute of Electrical and Electronics Engineers (IEEE) as ANSI/IEEE Std. 268-1992, and future revisions, will be the reference guide for definitions, symbols, abbreviations, and conversion factors.

It is the policy of ISA to encourage and welcome the participation of all concerned individuals and interests in the development of ISA standards. Participation in the ISA standards-making process by an individual in no way constitutes endorsement by the employer of that individual, of ISA, or of any of the standards, recommended practices, and technical reports that ISA develops.

This standard is structured to follow the IEC guidelines. Therefore, the first three clauses discuss the *Scope* of the document, *Normative References* and *Definitions*, in that order.

CAUTION — ISA ADHERES TO THE POLICY OF THE AMERICAN NATIONAL STANDARDS INSTITUTE WITH REGARD TO PATENTS. IF ISA IS INFORMED OF AN EXISTING PATENT THAT IS REQUIRED FOR USE OF THE STANDARD, IT WILL REQUIRE THE OWNER OF THE PATENT TO EITHER GRANT A ROYALTY-FREE LICENSE FOR USE OF THE PATENT BY USERS COMPLYING WITH THE STANDARD OR A LICENSE ON REASONABLE TERMS AND CONDITIONS THAT ARE FREE FROM UNFAIR DISCRIMINATION.

EVEN IF ISA IS UNAWARE OF ANY PATENT COVERING THIS STANDARD, THE USER IS CAUTIONED THAT IMPLEMENTATION OF THE STANDARD MAY REQUIRE USE OF TECHNIQUES, PROCESSES, OR MATERIALS COVERED BY PATENT RIGHTS. ISA TAKES NO POSITION ON THE EXISTENCE OR VALIDITY OF ANY PATENT RIGHTS THAT MAY BE INVOLVED IN IMPLEMENTING THE STANDARD. ISA IS NOT RESPONSIBLE FOR IDENTIFYING ALL PATENTS THAT MAY REQUIRE A LICENSE BEFORE IMPLEMENTATION OF THE STANDARD OR FOR INVESTIGATING THE VALIDITY OR SCOPE OF ANY PATENTS BROUGHT TO ITS ATTENTION. THE USER SHOULD CAREFULLY INVESTIGATE RELEVANT PATENTS BEFORE USING THE STANDARD FOR THE USER'S INTENDED APPLICATION.

HOWEVER, ISA ASKS THAT ANYONE REVIEWING THIS STANDARD WHO IS AWARE OF ANY PATENTS THAT MAY IMPACT IMPLEMENTATION OF THE STANDARD NOTIFY THE ISA STANDARDS AND PRACTICES DEPARTMENT OF THE PATENT AND ITS OWNER. ADDITIONALLY, THE USE OF THIS STANDARD MAY INVOLVE HAZARDOUS MATERIALS, OPERATIONS OR EQUIPMENT. THE STANDARD CANNOT ANTICIPATE ALL POSSIBLE APPLICATIONS OR ADDRESS ALL POSSIBLE SAFETY ISSUES ASSOCIATED WITH USE IN HAZARDOUS CONDITIONS. THE USER OF THIS STANDARD MUST EXERCISE SOUND PROFESSIONAL JUDGMENT CONCERNING ITS USE AND APPLICABILITY UNDER THE

USER'S PARTICULAR CIRCUMSTANCES. THE USER MUST ALSO CONSIDER THE APPLICABILITY OF ANY GOVERNMENTAL REGULATORY LIMITATIONS AND ESTABLISHED SAFETY AND HEALTH PRACTICES BEFORE IMPLEMENTING THIS STANDARD.

THE USER OF THIS DOCUMENT SHOULD BE AWARE THAT THIS DOCUMENT MAY BE IMPACTED BY ELECTRONIC SECURITY ISSUES. THE COMMITTEE HAS NOT YET ADDRESSED THE POTENTIAL ISSUES IN THIS VERSION.

The following served as voting members of ISA101 in the development of this standard:

NAME	AFFILIATION
G. Lehmann, ISA101Co-Chair	AECOM
M. Wilkins, ISA101 Co-Chair	Yokogawa IA Global Marketing USMK
J. Arbogast	American Air Liquide
J. Benitz, Jr.*	Gray Matter Systems
J. Bingham	AES Global Inc.
A. Bryant*	Oxy Inc.
P. Castro	Raizen - Jatai
T. Chaiket	Bergen County Utilities Authority
W. Cohen	Intel Corp.
C. Corbin	Holloman LLC
D. Deardorff	Metso Minerals Grinding
B. Fitzpatrick*	Wood Group Mustang
D. Ford	Westin Engineering, Inc.
G. Greco	Certainteed Gypsum
P. Gruhn (Alternate)	Rockwell Automation
W. Hollifield	PAS
T. Laabs*	Pfizer Global Manufacturing
L. Lang	Prosys
D. Lee*	UCDS
W. Lee	Degussa Evonik
D. Lutz	NOVA Chemicals
G. Nasby	Eramosa Engineering Inc.
I. Nimmo*	User Centered Design Services LLC
M. Nixon*	Emerson Process Management
J. Ollerhead	Fircroft Eng Services
K. Patel	Signature Automation
J. Price	ExxonMobil Chemical
D. Reed*	Rockwell Automation
N. Robinson	ABB Inc.
N. Sands*	DuPont
R. Schiedermayer	Object Technologies CEM Inc.
D. Schweitzer*	Eastman Kodak Co.
B. Vail*	URS PS / AECOM
B. Zakrajsek	Koch Modular Process Systems

\*Clause Editor

This published standard was approved for publication by the ISA Standards and Practices Board on 16 June 2015.

NAME	AFFILIATION
N. Sands, Vice President	DuPont
D. Bartusiak	ExxonMobil Research & Engineering
P. Brett	Honeywell Inc.
E. Cosman	OIT Concepts, LLC
D. Dunn	Phillips 66
J. Federlein	Federlein & Assoc. Inc.
B. Fitzpatrick	Wood Group Mustang
J. Gilsinn	Kenexis Consulting
J. Hauet	KB Intelligence
J. Jamison	Encana Corp.
K. P. Lindner	Endress + Hauser Process Solutions AG
V. Maggioli	Feltronics Corp.
T. McAvinew	Instrumentation and Control Engineering, LLC
V. Mezzano	Fluor Corporation
C. Monchinski	Automated Control Concepts Inc.
H. Sasajima	Azbil Corp.
T. Schnaare	Rosemount Inc.
J. Tatera	Tatera & Associates Inc.
K. Unger	Stone Technologies Inc.
I. Verhappen	Orbis Engineering Field Services
W. Weidman	WCW Consulting
J. Weiss	Applied Control Solutions LLC
M. Wilkins	Yokogawa IA Global Marketing (USMK)
D. Zetterberg	Chevron Energy Technology Co.

This page intentionally left blank.

## Contents

Introduction .....	9
Purpose .....	9
Organization .....	9
1 Scope .....	10
1.1 General Applicability .....	10
1.2 Exclusions .....	10
1.3 Intended Audience .....	10
2 Normative References .....	10
2.1 References .....	10
3 Definition of Terms and Acronyms .....	12
3.1 Definitions .....	12
3.2 Acronyms .....	18
4 HMI System Management .....	19
4.1 Introduction .....	19
4.2 System Standards .....	20
4.3 The Design Process .....	23
4.4 The Implementation Stage of the HMI Lifecycle .....	27
4.5 The Operate Stage of the HMI Lifecycle .....	30
4.6 Continuous Work Processes .....	32
5 Human Factors Engineering & Ergonomics .....	35
5.1 General Principles of HMI Design .....	35
5.2 User Sensory Limits .....	36
5.3 User Cognitive Limits .....	39
6 Display Styles and Overall HMI Structure .....	40
6.1 Introduction .....	40
6.2 Display Styles .....	40
6.3 Display Hierarchy .....	42
7 User Interaction .....	47
7.1 Introduction .....	47
7.2 Software Methods for User Interaction .....	47
7.3 Hardware Interfaces .....	57
8 Performance .....	59
8.1 Introduction .....	59
8.2 HMI Categories .....	59
8.3 HMI Duty Factors .....	60
9 Training .....	61
9.1 User Training .....	61

### Figures

Figure 1 – Selected HMI Terms and Their Interrelationships .....	17
Figure 2 – HMI Lifecycle .....	19
Figure 3 - Sample Level 1 Display.....	43
Figure 4 - Sample Level 2 Display.....	44
Figure 5 - Sample Level 3 Display.....	45
Figure 6 - Sample Level 4 Display.....	46
Figure 7 – Batch Application Navigation Normal Operations Example .....	52
Figure 8 – Plant-wide Navigation Example .....	53

### Tables

Table 1 – System standards stage activities .....	21
Table 2 – Design stage activities .....	24
Table 3 – Implement stage activities .....	27
Table 4 – Operate stage activities.....	31
Table 5 – Continuous work processes stage activities .....	33
Table 6 – Display styles.....	40
Table 7 – Example numeric decimal formatting .....	48
Table 8 – Example access and navigation performance.....	55

## Introduction

### Purpose

The purpose of this standard is to address the philosophy, design, implementation, operation, and maintenance of Human Machine Interfaces (HMIs) for process automation systems, including multiple work processes throughout the HMI lifecycle. It is also intended to help users to understand the basic concepts as a way to better and more readily accept the style of HMI that the standard is recommending.

The standard defines the terminology and models to develop an HMI and the work processes recommended to effectively maintain the HMI throughout the lifecycle. Use of this standard should:

- a) provide guidance to design, build, operate and maintain HMIs to achieve a safer, more effective, and more efficient process control system under all operating conditions.
- b) improve the user's abilities to detect, diagnose, and properly respond to abnormal situations.

The HMI is the collection of hardware and software used to monitor and interact with the control system and ultimately with the process.

The target audiences are end users, designers, developers, and implementers of HMI systems.

### Organization

This standard is organized into nine clauses. The first three clauses are introductory in nature. Clause 4 presents the lifecycle model for the HMI. Clauses 5 through 9 provide additional details to support the lifecycle. The main body of the standard (Clauses 4-9) presents mandatory requirements and non-mandatory recommendations as noted. If a clause contains mandatory requirements, it is noted at the beginning of the clause.