

Multiple Sources and One Pipe: Using Hydraulic Analysis to Model Source Water Composition Changes in the Arkell Aqueduct




C3 WATER


Background

The Arkell Aqueduct and F.M. Woods
Water Treatment Plant


Arkell Aqueduct



Water Sources




Water Sources




- Groundwater (GW)
- Groundwater Under the Direct Influence of Surface Water with Effective Filtration (GUDI-WEF)

Treatment



Model Development

Model




Goals:

- Isolate and drain the aqueduct
- Introduce only GW sources

Assess:

- Risk of manhole flooding during draining
- GW source interface time of travel


Model Development




Equations:

- Darcy-Weisbach
- Manning's


Model Inputs



Model Calibration




Model Calibration




Model Results

Hydraulic Capacity and Flood Risk



Hydraulic Capacity and Flood Risk



Draining Time

Planned UV Shutdown


- Remove GUDI-WEF sources
- Time for initial GW + GUDI-WEF storage volume to clear aqueduct

Emergency UV Shutdown

- Aqueduct isolation butterfly valves will close at F.M. Woods
- Aqueduct drain line into Eramosa River will open
- Remove GUDI-WEF sources

Time of Travel


Model Output:
Pipe Storage
Volume



$$ToT = \frac{V}{Q}$$

Model Input:
System Flow

Steady State Modelled Travel Time Curve: Woods R1 Level at 311.5m




SOURCE WATER CHARACTERIZATION AND PCN

PCN Development

- Develop travel time curves for the aqueduct using the PCSMM model
- Determine when a GUDIWEF or GW changeover occurs at production
- Determine when the GUDIWEF/GW interface will reach treatment
- Update SCADA output real-time to reflect what is actually being treated and when a change-over is estimated to occur


Time of Travel



$$\sum_{i=0}^t \frac{\Delta t}{T_oT_i} = \text{Cumulative percentage advance (dimensionless)}$$

Where:

- Δt = Time elapsed since last routine (5 minutes)
- T_oT_i = Calculated time of travel from SCC to Woods, or from MH101 to SCC in minutes



F.M. Woods Source Water Characterization
 Process Control Narrative
 DRAFT 2017/03/21

	Output		Calculated Data
	Process		Process Path
	Conditional		Data Grab
	Database		Data Write

AUTOMATION

How do I program this into SCADA?


- How are operators going to use this tool?
- Process data inputs?
- Expected outputs?

- Design of user interface on screen?
- How do I structure the internal PLC code?
- How to fit this within the existing SCADA System?

- **How can I test/verify the code?**

PCN to SCADA Programming

- We found the flowchart PCN provided a good operational description for people to understand how the flow model would work
- **But...**
The algorithm in the PCN would be very hard to test, as it has multiple decision structures/calculations that run every 5 mins
- Changed PCN algorithm into a step-wise Excel-based model
- Resulting Excel spreadsheet:
 - ▷ Each row is a 5 min iteration
 - ▷ 52 columns: 7 inputs, 37 internal-calcs/if-then, 8 outputs
 - ▷ Uses standard Excel functions (no VB or macros)



F.M. Woods Source Water Characterization
Process Control Narrative
DRAFT 2017/03/21

	Output		Calculated Data
	Process		Process Path
	Conditional		Data Grab
	Database		Data Write

Selecting PLC to Use

- Three choices for programming model calculations:
 - ▷ Programming in PLC
 - ▷ Scripting on a SCADA server
 - ▷ Write custom add-on application
- **Selected the PLC-based approach**
 - ▷ Had to use a modern PLC. We used a dedicated PLC for project
 - ▷ Tag-based memory (not numbered registers)
 - ▷ Data Structures (user-defined complex-datatypes) in Arrays
 - ▷ Support for “Structured Text” programming
 - ▷ Support for user-defined function blocks

Mock-up of SCADA HMI Interface


GUDIWEF SOURCE STATUSES AND MANUAL OVERRIDE

Arkell 1 Status	OFF	Arkell 1 Override	<input type="checkbox"/>
Arkell 15 Status	OFF	Arkell 15 Override	<input type="checkbox"/>
G.C. Prod. Status	OPEN	G.C. Prod. Override	<input type="checkbox"/>
Carter 1 Status	ON	Carter 1 Override	<input checked="" type="checkbox"/>
Carter 2 Status	ON	Carter 2 Override	<input checked="" type="checkbox"/>

INPUT DATA
(from SCADA)



MODEL OUTPUT
(for operators)



CURRENT
PRODUCTION SOURCE
CHARACTERIZATION

GUDIWEF


CURRENT TREATMENT
SOURCE
CHARACTERIZATION

Groundwater

TIME TO CHANGE IN
SOURCE WATER AT
TREATMENT

1 st Change	150 min
2 nd Change	N/A
3 rd Change	N/A
4 th Change	N/A
5 th Change	N/A
6 th Change	N/A


Final HMI Screen Design – MODEL INPUTS & Calcs



Final HMI Screen Design – MODEL OUTPUTS & PLOT

OUTPUTS										
Source Water Changes				Slugs of Water						Status
Time to Woods		N/A Irrelev.		Type	End of Slug		Start of Slug		N/A	Current Production Status 0 = GW 1 = GUDI
1	2	3	4		Time away from Woods	Arrival Time at Woods	Time away from Woods	Arrival Time at Woods		
1	188.53	min	0	0	1	188.53	18:12	0.00	15:03	0
2	244.84	min	0	0	2	244.84	19:08	188.53	18:12	0
3	0.00	min	1	0	3	279.89	19:43	244.84	19:08	0
4	0.00	min	1	0	4	340.74	20:44	279.89	19:43	0
5	0.00	min	1	0						
6	0.00	min	1	0						

0 = GW
1 = GUDI



Final HMI Screen for Model



Woods Aqueduct Model

ADMIN1

ADMIN is logged in

MENU

7:18:01 PM

02/10/2018



Arkell

Flow	Simulation Status
Arkell 1* 0.00 L/s	REAL <input checked="" type="checkbox"/> ON <input type="checkbox"/> OFF
Arkell 6 86.05 L/s	
Arkell 7 84.11 L/s	
Arkell 8 0.00 L/s	
Arkell 14 0.00 L/s	
Arkell 15* 84.70 L/s	REAL <input checked="" type="checkbox"/> ON <input type="checkbox"/> OFF
Glen Collector* 122.26 L/s	
Total 377.01 L/s	Note: It takes 5 mins for model to reflect a change.

* = GUDIWEF Source

Carter

Flow	Simulation Status
Pump 1* 41.29 L/s	REAL <input checked="" type="checkbox"/> ON <input type="checkbox"/> OFF
Pump 2* 27.05 L/s	
Total 68.34 L/s	Note: It takes 5 mins for model to reflect a change.

* = GUDIWEF Source

Manhole 101

Total Production

GW **170.17** L/s

GUDIWEF **206.96** L/s

Woods

UV Units: 1 2 3

UV Total Flow: **377.98** L/s

Water at Woods UV: **GUDI**

Time to Next Source Change: **N/A** min

Reservoirs:

1	4.87	
2	3.87	
3	5.55	
4	4.46	
5	3.75	
6	3.36	

Boosters:

1	
2	
3	
4	
5	

88 psi

604.6 kPa

1.14 mg/L

370.86 L/s

Note: Model is based on only pump run statuses, total flow at Woods UV, and Woods Res 1 level. (Other flows/levels not used.)

Based on PC SWIM flow model developed by C3 Water July 2017. PLC code updated Aug 31/2017.

Alarm Summary

Algorithm Data

INPUTS	INTERNAL				Counters	Source Water Changes		OUTPUTS				
	Production		Interfaces			Interface Counter		Slugs of Water		Status		
Inputs used for last calculation, not live	MH101 Production		MH101 to Scout Interfaces		Beginning		1 0.00 min 1 0		Type 1 1		Current Production Status	
1 = Running/Producing	MH101 > Scout Time		Scout to Woods Interfaces		After Advance		2 0.00 min 1 0		1 179.21		1 = GUDIWEF	
Arkell Well 1	50.3 min		Time: 0.00 1 0.00 1 0.00 1 min		0 0		3 0.00 min 1 0		2 0		1 1	
Arkell Well 15	75.17 %		Start: 0.0000 1 0.0000 1 0.0000 1 %		0 0		4 0.00 min 1 0		3 1		1 = GUDIWEF	
Glen Collector	Woods UV Flow		End: 0.0000 1 0.0000 1 0.0000 1 %		Number of Slugs		5 0.00 min 1 0		4 0		Current Treatment Status	
Carter Well 1	375.34 L/s		Time: 0.00 1 0.00 1 0.00 1 min		1		6 0.00 min 1 0		5 0		1 1	
Carter Well 2	Scout > Woods Time				0				6 0		1 = GUDIWEF	
	3.9 %											

Final HMI Screen Design



Woods Aqueduct Model

NODE


ADMIN

is logged in

MENU

3:03:10 PM

22/08/2017



Arkell	Flow	Simulation Status
Arkell 1	0.00 L/s	REAL ON OFF
Arkell 6	82.96 L/s	REAL ON OFF
Arkell 7	73.99 L/s	REAL ON OFF
Arkell 8	0.00 L/s	REAL ON OFF
Arkell 14	80.67 L/s	REAL ON OFF
Arkell 15	0.00 L/s	REAL ON OFF
Glen Co.	136.17 L/s	REAL ON OFF
Total	373.90 L/s	REAL ON OFF

Carter	Flow	Simulation Status
Pump 1	29.43 L/s	REAL ON OFF
Pump 2	28.03 L/s	REAL ON OFF
Total	57.45 L/s	REAL ON OFF

Woods	Reservoirs	Boosters
UV Total Flow	4.97	1 A S
Water at Woods UV	3.98 m	2 A S
GUDI	4.56 m	3 A S
Time to Next Source Change	188.53 min	4 A S
	3.56 m	5 A S

93 psi

639.0 kPa

1.26 mg/L

359.67 L/s

Based on PC SWM flow model developed by C3 Water July 2017 PLC code updated Aug 31/2017.

Alarm Summary

Algorithm Data

INPUTS	
Inputs used for last calculation, not live	
1 = Running/Producing	
Arkell Well 1	0 Woods Res 1 Lvl
Arkell Well 15	0 80.08 %
Glen Collector	0 Woods UV Flow
Carter Well 1	1 171.56 L/s
Carter Well 2	0

Production		INTERNAL Interfaces			
MH101 Production	0 59.8 min	1	N/A	2	N/A
MH101 > Scout Time	8.4 %	0.0000	1	0.0000	1
Scout Production	1 279.9 min	0.0000	1	0.0000	1
Scout > Woods Time	1.8 %	0.3264	0	0.1252	0
Scout > Woods Incr.		0.0000	1	0.0000	1
		188.53	0	244.84	0

Counters	
Interface Counter	
Beginning	0 2
After Advance	0 2
Number of Slugs	
Start of GUDI Slug at Scout	1

Source Water Changes	
Time to Woods	1 188.53 min 0 0
Time to Woods	2 244.84 min 0 0
Time to Woods	3 0.00 min 1 0
Time to Woods	4 0.00 min 1 0
Time to Woods	5 0.00 min 1 0
Time to Woods	6 0.00 min 1 0

OUTPUTS		Slugs of Water				Status
Type	Time away from Woods	Arrival Time at Woods	Time away from Woods	Arrival Time at Woods	Status	N/A
1	188.53	18:12	0.00	15:03	1	1 = GUDI
2	244.84	19:08	188.53	18:12	0	Current
3	279.89	19:43	244.84	19:08	0	Treatment
4	340.74	20:44	279.89	19:43	0	Status
5					1	1 = GUDI

Acknowledgements

C3 Water

- ▶ Dennis Mutti: Project Manager
- ▶ Nathan Valsangkar: Model Development



City of Guelph

- ▶ Shawn Hustins: SCADA Programming





THANK YOU!

Any questions?